

GOVERNMENT OF ANDHRA PRADESH  
Rural Water Supply & Sanitation Department  
R.W.S. I.W.Q.M. LABORATORY, Z.P. Compound, Srikakulam.

SAMPLE RECEIVED FROM The Internatinal Delhi Public School Vadada Jn,Vappangi (Rural) Srikakulam.

RECEIVED DATE: 20.03.2024

COLLECTED By : K Charan Sahu

Dist: Srikakulam

Sl.No	Lab Ref. No.	Mandal	Name of the Gramapanchayat	Name of the Habitation	Source (BW, OW, Sch)	Location	Code	Date of Collection	Date of Testing	pH (6.5-8.5)	Electrical Conductivity micromhos/cm 200-2000M	Total Dissolved Solids 500-2000mg/lit	Total Alkalinity as CaCo3 200-600 mg/lit	Total Hardness as CaCo3 300-600 mg/lit	Fluoride as F 1.0-1.5 PPM	Chloride Cl 250-1000 mg/lit	Calcium 75-200 mg/lit	Sulphate as SO4 200-400 mg/lit	Iron as Fe 0.3 - 1.0 mg/lit	Turbidity 5-10 NTU	Magnesium 50-150 mg/lit	Nitrate as No3 45 mg/lit	Remarks
1	32	Srikakulam	Vappangi	Vappangi	RO	The Internatinal Delhi Public School Vadada Jn,Vappangi (Rural) Srikakulam.		20.03.2024	20.03.2024	7.13	235	152	36	56	0.06	25	9	5.4	0.44	0.4	8.141	21	Satisfactory

*P.S.*  
20/03/24  
Lab Chemist  
RWS&S IWQM Lab  
Srikakulam

For Global Educational Society

*[Signature]*  
SECRETARY

*[Signature]*  
Head Master  
International Delhi Public School  
Vadada Junction, Arasavalli  
Srikakulam-532401