

FIRE SAFETY CERTIFICATE

No.R.CN.o.10440/MSB/ER/SKLM/2022

Dated:25/01/2023

Certified that the International Delhi Public School (name of the building or premises) at Vadada Jn, Voppangi Panchayati, Voppangi(rural), Srikakulam (address) comprised of Ground basement(s) and 2 (upper floors) owned/ occupied by International Delhi Public School (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 12/01/2023 (date of inspection) in the presence of Sri M.Satya Prasad (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes X (X/ XII) With effect from 25/01/2023 for a period of 24/01/2026 year in accordance with rule and subject to compliance of specific conditions as appended:-

- 1.
- 2.
- 3.
- 4.

Issued on 25/01/2023 (date of issue) at State Disaster Response and Fire Service AP Vijayawada (place) by Director General.

*Strike out whichever is not applicable.

Signature with Seal (B. VEERABHADRA RAO) 31/05/2023
 Name : Response & Fire Officer
 Srikakulam
 Designation :
 Name & Address of Department/ Office :
 Office of the District Disaster Response & Fire Officer
 Srikakulam

To

The Director,
 International Delhi Public
 School, Vadada Jn.,
 Voppangi Panchayati,
 Voppangi Rural,
 Srikakulam.
 (Name & Address of the Institution)



ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

 (reasons to be recorded).

(Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

For Global Educational Society

[Signature]
 SECRETARY

[Signature]
 Head Master
 International Delhi Public School
 Vadada Junction, Arasavalli
 Srikakulam-532401

GOVERNMENT OF ANDHRA PRADESH
A.P. STATE DISASTER RESPONSE AND FIRE SERVICES DEPARTMENT

From:
The Director General,
State Disaster Response & Fire Services,
Andhra Pradesh, Vijayawada.

To:
The District Educational Officer,
Srikakulam District.

Rc.No.10440/MSB/ER/SKLM/2022, Dated: 25-01-2023.

Sir,

Sub:- A.P State Disaster Response & Fire Services Department - MSB Section - Eastern Region - Issuance of No Objection Certificate for Occupancy to the Existing Multi Storied Building of M/s International Delhi Public School, Sy.No.198/1,2,3,200/6, Voppangi Village and Panchayat, Srikakulam Mandal, Srikakulam District - Regarding.

- Ref:-
1. Application of M/s International Delhi Public School, Sy.No.198/1,2,3,200/6, Voppangi Village and Panchayat, Srikakulam Mandal, Srikakulam District.
 2. This Office Memo Rc.No.10440/MSB/ER/SKLM/2022, Dt:06-01-2023.
 3. Inspection Officer Report Rc.No.12/ADFO/SKLM/2022, Dt:13-01-2023.

<<0>>


The Management has requested for issuance of No Objection Certificate for Occupancy to the Existing Building of M/s International Delhi Public School, Sy.No.198/1,2,3,200/6, Voppangi Village and Panchayat, Srikakulam Mandal, Srikakulam District vide reference 1stcited.

- 2) The Management has constructed the Building with Ground + (02) Upper Floors with a height of 09.00 Mtrs., with a total Built-up area of 1816.29 Sq.Mtrs., for Educational Occupancy.
- 3) The Management has not obtained Provisional No Objection Certificate from this Department and now applied for No Objection Certificate for Occupancy.
- 4) The Multi Storied Building Inspection Officer has inspected the premises of M/s International Delhi Public School, Sy.No.198/1,2,3,200/6, Voppangi Village and Panchayat, Srikakulam Mandal, Srikakulam District on 12-01-2023, scrutinized the plans of above Existing Multi Storied Building and submitted the following report vide reference 3rd cited.

5) Particulars of the Building:

a) Name & Address of the Building	:	M/s International Delhi Public School, Sy.No.198/1,2,3,200/6, Voppangi Village and Panchayat, Srikakulam Mandal, Srikakulam District.
b) Total Plot/Site Area	:	1897.24 Sq.Mtrs.,
c) Height of the Building	:	09.00 Mtrs.,
d) No. of Floors	:	Ground + (02) Upper Floors
e) Total Built-up Area	:	1816.29 Sq.Mtrs.,
f) Type of Occupancy	:	Educational Occupancy

For Global Educational Society


SECRETARY


Headmaster
International Delhi Public School
Vadada Junction, Atkasavalli
Srikakulam-532401

4) Following are the Floor wise details of Existing Building total Built-up area.

Sl.No.	Floor	Built-up area (In Sq.Mtrs.,)	Type of Occupancy (as per Clause 3.1 part-IV of NBC, 2016)
1.	Ground	731.26	Educational
2.	First	731.26	Educational
3.	2 nd Floor	353.77	-
	TOTAL	1816.29	

5) The Management has provided the following Means of Escape.

Sl. No.	Details of Means of Escape	Minimum width required (as per clause 4.4 Part-IV of NBC, 2016)		As found in the inspection		Location	Deficit or Opinion of the Inspection Committee/ Officer
		No.'s	Width (in Mtrs.,)	No.'s	Width (in Mtrs.,)		
1.	Internal Staircase	01	01.50	01	01.00	Middle	The Stair Case is free from any Obstruction
2.	External Staircase	01	01.25	01	01.00	Middle	
	Total:	02	2.75	02	02.00		


6) The details of Occupant Load per Unit and Exit Width required and provided are furnished as below:

Sl. No.	Floor	Built Up Area (In Sq.Mtrs.,)	No. of Occupants	Means of escape Required (as per clause 4.4 Part-IV of NBC-2016) in Mtrs.,	As found in the inspection (in Mtrs.,)	Deficit or Opinion of the Inspection Committee/ Officer
1.	Ground	731.26	182	2.50	Provided sufficient No.of doors	
2.	1 st First	731.26	182	2.50	02.00	
3.	2 nd Floor	353.77	88	2.50	02.00	
	TOTAL	1816.29				

7) Further, we submit that, the Builder has provided the following Fire Fighting systems as per Table-07 of NBC, 2016.

Sl. No.	Fire Fighting Installations	Required	As found in the inspection	Deficit or Opinion of the Inspection Committee/ Officer
1.	Fire Extinguishers	18 No.'s	18 No.'s	During the inspection all the equipment are in working condition
2.	Hose Reel	03 No.'s	02 No.'s	
3.	Down Comer System	01 No	01 No	
4.	Terrace water Tank	10,000 Ltrs	10,000 Ltrs	
5.	Fire Pump	450 LPM	450 LPM	

For Global Educational Society


SECRETARY

International Delhi Public School
Vadada Junction, Arasavalli
(Contd. 53.3p)

8) Electrical Safety:

Sl.No.	Description	Compliance
1	Whether Provided MCB's for each Floor ?	Yes
2	Whether provided Emergency lighting at Corridors/ Common passages and Staircases with UPS backup ?	Yes

9) The Management has provided minimum Fire Safety measures as per Table-7 of Part-IV of NBC-2016 and the Inspection Officer has tested the Fire safety systems and found in working condition.

10) The Management is responsible all risks involved in case of Fire Accident.

11) In view of the above and based on the recommendation of the Inspection Officer, the No Objection Certificate for Occupancy is hereby issued to the M/s International Delhi Public School, Sy.No.198/1,2,3,200/6, Voppangi Village and Panchayat, Srikakulam Mandal, Srikakulam District.

12) It is informed that, the Management of M/s International Delhi Public School, Sy.No.198/1,2,3,200/6, Voppangi Village and Panchayat, Srikakulam Mandal, Srikakulam District is requested to maintain the following conditions compulsorily for safety purpose.


Sl.No.	As Builder	As Occupant	As Security Personnel
1.	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2.	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months.
3.	Addition/alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4.	This No objection Certificate for occupancy is only in fire safety point of view.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

For Global Educational Society

[Signature]
SECRETARY

Head Master
International Delhi Public School
Vadachanction, Arasavalli
(Contd... 4p)
Srikakulam-532401

15) This No Objection Certificate for Occupancy is valid for a period of Three (03) years only from the date of issue of this letter to the Management of M/s International Delhi Public School, Sy.No.198/1,2,3,200/6, Voppangi Village and Panchayat, Srikakulam Mandal, Srikakulam District. It is the responsibility of the builder to apply for Renewal of No Objection Certificate for Occupancy, duly remitting the User Charges as per G.O.Ms.No.90, Home (Prisons & Fire Services) Department, Dated.13-08-2021 and G.O.Ms.No.120, Home (Prisons & Fire Services) Department, Dated.25-10-2021, two (02) months before expiry of this No Objection Certificate.


Director General,
State Disaster Response and Fire Services,
Andhra Pradesh, Vijayawada.


24/1/23


Copy to the Management, M/s International Delhi Public School,
Sy.No.198/1,2,3,200/6, Voppangi Village and Panchayat, Srikakulam Mandal,
Srikakulam District.

Copy to the District Disaster Response & Fire Officer, Srikakulam District.

Copy to the Asst District Fire Officer, Srikakulam Fire Station.

For Global Educational Society


SECRETARY


Head Master
International Delhi Public School
Vadada Junction, Arasavalli
Srikakulam-532401